

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO.		3. EFFECTIVE DATE		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)	
6. ISSUED BY		CODE		7. ADMINISTERED BY (If other than Item 6)		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NO.	
						9B. DATED (SEE ITEM 11)	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 11)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).						
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
	D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR				15C. DATE SIGNED		16B. UNITED STATES OF AMERICA	
(Signature of person authorized to sign)						(Signature of Contracting Officer)	
				16C. DATE SIGNED			

Block 14. DESCRIPTION OF AMENDMENT (cont.)

1. The following provides the Government's response to preaward inquiries:

Date Submitted	REFERENCE			QUESTION	GOVERNMENT RESPONSE
	Page	Section	Para.		
9/15/2020	PD401 PD402 P-401 P-402 P-403			In the plumbing demo drawings it is indicated that the fixtures are to be demolished and replaced and the main runs of pipe down the chase is to remain, but the notes say that all the pipe on the first floor is to be demolished. The new work drawings show the new pipe connecting to the existing main lines, but the notes mention the first floor piping being demolished. It is unclear how much of the first floor piping is being demolished and where the connections of the new pipe to the existing will be. Examples of conflict are on, but not limited to, PD402 and Keynote DP03. An example of new connecting to existing on P-401, but conflicts with note P01. Notes P07 and P11 on the same page conflict with demo drawings. Same with the domestic on page P-402 and P-403. Please, clarify if possible.	Intent of the Keynotes is correct. All plumbing fixtures throughout the building are to be demolished. All domestic and sanitary piping, located in the chase, serving the first floor, shall be demolished to the associated fitting between the first and second floors. Domestic and sanitary piping, located in the chase and serving the second and third floors, is to remain for re-use. Sanitary and domestic piping serving the washing machines in laundry rooms, 121, 221, and 321 will be demolished and replaced to the connection point indicated on the drawings. Sanitary piping connected to the floor drains in laundry rooms 221 and 321 is to remain. Demolition of the concrete for floor drains is indicated on the structural drawings. All keynotes are correct. (Phasing issues with the software led to half tone piping.)
9/16/2020	MD40 2			The notes say to remove existing thermal unit and all associated ductwork, grilles and diffusers complete. The drawing shows ductwork in each room that appears to be attached to a thermal unit, but does not show a thermal unit. Is there a thermal unit in each room?	Yes there is a thermal unit in each room that will need to be demolished.
9/16/2020				Door schedule notes blast resistant doors "type 1" & "type 2" for unit entries. There is a blast spec but it omits much of the key info needed (i.e stand off distance, charge weight, level of protection). I did not find this info on the structural drawings either. Please clarify.	Design criteria is provided in spec 08 39 54 paragraph 2.5.1.2

9/16/2020				One unit entry door notes HW set #17 and the other notes HW set #1. HW set #17 notes all hardware provided by blast door supplier. HW set #1 notes hardware, but does not mention blast, even though the door schedule notes these doors as blast resistant doors. Blast doors typically swing out of the building. This allows the stop of the frame to assist with the blast. These doors are inswinging. The hardware noted in HW set #1 will most likely not meet the requirements for an inswinging door. Please clarify which HW set is to be used.	Blast resistant Sleeping Room entry doors, both Type 1 & 2, shall receive hardware set #17. Set #17 shall include the card key lockset by the hardware supplier, all other door hardware is by the blast door manufacturer.
-----------	--	--	--	---	---

A. All other contract terms and conditions remain unchanged.