

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 3 PAGES	
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0003		3. EFFECTIVE DATE 01/06/22		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable) 21-0038	
6. ISSUED BY CODE		N40085		7. ADMINISTERED BY (If other than Item 6) CODE			
NAVFAC Mid-Atlantic Resident Officer in Charge of Construction 1005 Michael Road Camp Lejeune, NC 28547-2521				See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NO.	
				X		N40085-22-R-2574	
						9B. DATED (SEE ITEM 11) 12/15/21	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 11)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).						
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
	D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) 21-0038, STRUCTURAL REPAIRS Bldg FC270  Amendment 0003, RFI Responses  The time and date for receipt of proposals remains 1400, 14 January 2022.  This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of a proposal.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)				(Signature of Contracting Officer)			

## CONTINUATION SHEET

**1. QUESTION:** Will leaking exterior faucets be fixed or are they all to replace during the job?

ANSWER: All exterior faucets/hose bibs are to be replaced as per Elevation Key Notes #2 on sheets A301 & A302. In addition to hose bibs shown on elevations 1/A301 & 1/A302 contractor to replace exterior hose bib not shown on 1/A302 NORTH ELEVATION adjacent to double louver doors and below exhaust fan.

**2. QUESTION:** Preparation specifically of bollards and gutter boots is remove rust, prime and paint in the job description, to do not disturb on A 101, all the way to sandblasting on A 301. Being that the facility is open throughout the contract might sandblasting be excessive as there are other ways to handle rust. Please advise.

ANSWER: As per keynote 3 on sheet A101 sandblasting is required to remove mold and stains. Sandblasting Bollards and downspout boots required as per sheets A301 & A302

**3. QUESTION:** If the roof fan curbs (shown on drawing A201) will need to be replaced we will need to know what size curbs will be required. This can be obtained by either measuring the existing curbs (length, width, height) or by referencing the existing Roof fan make/model number and searching for a submittal/instruction manual. Our vendors will need to know this information.

ANSWER: Contractor is required to field verify all existing conditions as per construction documents.

**4. QUESTION:** Note 3 on drawing A201 tells us to disconnect equipment, demo roof curb, and to salvage/store equipment for re-installation. Are the existing roof curbs to be trashed or stored for re-use?

ANSWER: As per Note 3 on Drawing A201 Demo Roof Curb and Provide New Roof Curb.

**5. QUESTION:** If the roof curbs are to be replaced with new, what is the dimensions and quantities of each size for the new roof curbs?

ANSWER: Contractor is required to field verify all existing conditions as per construction documents.

**6. QUESTION:** The make/model number of the existing roof fans is unknown, what is the make/model of the existing roof fans?

ANSWER: Contractor is required to field verify all existing conditions as per construction documents.

**7. QUESTION:** There appears to be a total of 11 ea roof fans to remove/replace on drawing A201. Is that the correct amount of fans?

ANSWER: Contractor is required to field verify all existing conditions as per construction documents.

**8. QUESTION:** Per note 2 on drawings A301 & A302 there appears to be numerous hose bibs that are to be removed and replaced with new. Will the water system require chlorination/disinfection after the new hose bibs are installed?

ANSWER: Yes. Water system will require chlorination/disinfection after the new hose bib is installed.

**9. QUESTION:** Is there a preferred make/model of wall hydrant?

ANSWER: Provide new hose bib with vacuum breaker.

**10. QUESTION:** Our Insurance underwriters have asked what year building FC270 was constructed and its total square footage.

ANSWER: Building was constructed in 1988. 22,866 total square feet.

**11. QUESTION:** In regard to Activities outlined for the bollards:

\*The Scope of Work states, "Remove rust, prime and paint... Bollards."

\*SHT. A101 – Floor Plan Level 1 Notes states, "Bollards – Do Not Disturb, Protect as Necessary"

\*SHT. A301 – Elevation Notes – Typical All Conditions states, "Bollards – Sandblast, Prepare for Painting – Paint"

Please advise which approach is desired, understanding that there are multiple methods available to remove rust and that sandblasting may be an extreme tactic within an occupied building. Our Insurance underwriters have asked what year building FC270 was constructed and its total square footage.

ANSWER: As per keynote 3 on sheet A101 sandblasting is required to remove mold and stains. Sandblasting Bollards and downspout boots required as per sheets A301 & A302

**12.** All other terms and conditions remain unchanged.