

1. CONTRACT ID CODE		PAGE		OF PAGES	
J		1		3	
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 04/05/2022		4. REQUISITION/PURCHASE REQ.	
				PROJECT NO. (If applicable)	
6. ISSUED BY NAVFAC MID ATLANTIC CONTRACTING CORE 9324 VIRGINIA AVENUE NORFOLK, VA 23511		Code N40085		7. ADMINISTERED BY (If other than item 6.)	
				Code	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. N40085-22-R-2637
				<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) 03/10/2022
				<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (if required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).				
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
<input type="checkbox"/>	D. OTHER: (specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
N4008522R2637 P1289 ORDNANCE OPERATIONS SUPPORT & INERT STORAGE REPLACEMENT, WEAPONS COMPOUND, NAS OCEANA, VIRGINIA BEACH, VA					
SEE SF 30 BLOCK 14 CONTINUATION PAGE					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Same as Item 8)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA	
(Signature of person authorized to sign)				BY	
				(Signature of Contracting Officer)	
				16C. DATE SIGNED	

SUMMARY OF CHANGES

AMENDMENT 0002

The purpose of this amendment is to provide the following:

1. Site Visit Attendance

PDF Attachment: 22R2637 Site Visit Attendance

Solicitation: N40085-22-R-2637

Site Visit Date and Time: 24 March 2022 at 0900 EST

Site Visit Location: NAS Oceana, Virginia Beach, Virginia

2. Response to Pre-Proposal Inquiries (PPIs)

Solicitation: N40085-22-R-2637

Pre-Proposal Inquiry Submission Form N4008522R2637 P1289 ORDNANCE OPERATIONS SUPPORT & INERT STORAGE REPLACEMENT					
PPI#	Reference			Question	Response
	Page	Section	Paragraph		
1	Clin 0007/0010	Clin 0007/0010	Clin 0007/0010	For clarification purposes is the contractor to price the remediation of contaminated soil prior to results of a soils report? If so for the purpose of bidding please provide a quantity of soil that is to be removed	Quantities and units have been provided for each CLIN in the provided Supplementary Instructions to Offerors (00 22 13.00 20).
2	3	General Requirements	Description of the Work	Will the government provide drawing for all of the new PEMB building for this project?	No, No additional drawings will be provided by the government. Bid per RFP.
3	3	General Requirements	Description of the Work	Will weekend work be allowed?	No, Bid Per RFP Part 2, Section 01 14 00.05 20 paragraph 1.2d, "Contractor work hours are between 0700 and 1530 <u>Monday through Friday</u> , excluding Government holidays."
4	3	General Requirements	Description of the Work	Will the government provide electrical, plumbing and HVAC plans?	No, bid per RFP.

5	3	General Requirements	Description of the Work	Will the government be providing a Commissioning Agent, or will the contractor be responsible for providing?	Bid Per RFP Part 3, Paragraph 2.2, Commissioning is not required for the project as a whole.
6	3	General Requirements	Description of the Work	Please clarify if a superintendent can be a triple hat to cover the requirements of SSHO and QA/QC?	Bid Per RFP Part 2, Section 01 30 00.05 20 Paragraph 1.1, "The Superintendent <u>may not</u> serve as the site Safety and Health Officer." Per RFP Part 2, Section 01 45 00.05 20 Paragraph 1.2, "The Superintendent <u>may not</u> serve as the Quality Control Manager on this project."
7	3	General Requirements	Description of the Work	Please provide specs for PEMB requirements?	Noo, bid per RFP. See RFP Part 3, Sections B10 and F10, and Part 4, Section F1010 for PEMB requirements.
8	3	General Requirements	Description of the Work	What are the interior finish requirements? a. Flooring? Sealed concrete, or something else? b. Exposed CMU walls or PEMB Insulation, or drywall? Contractor assumes exposed CMU or drywall, if used, would be painted. c. Acoustic Ceilings or exposed to deck?	Interior finishes are covered under RFP Part 3, section C10 and C30. Further room-by-room requirements are provided in RFP Part 3, Section 5.0, "Room Requirements". Option Item No. 3 information is also contained in individual Room Requirement sheets.
9	3	General Requirements	Description of the Work	Is Interior or exterior signage required?	Yes. Signage, in accordance with UFC 3-120-10 is required per RFP Part 3, Section C1030.
10	3	General Requirements	Description of the Work	Rain gutter and downspouts with splash blocks required?	Yes. Gutters and Downspouts are required per RFP Part 3, Section B3010. Splash blocks are required per RFP Part 4, Section B3010, Paragraph 3h.

(End of Summary of Changes)