

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1	OF PAGES
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 7/29/2022	4. REQUISITION/PURCHASE REQ. NO. 7103883	5. PROJECT NO. (If applicable)		
6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-87, 748 Roosevelt Blvd. PSC BOX 8006 CHERRY POINT, NC 28533		7. ADMINISTERED BY (If other than item 6.)		Code	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL			<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION Interior Upgrades Station Safety Office B901	
				9B. DATED (SEE ITEM 11)	
			<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☐ is extended ☒ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

7103883 Interior Upgrades Station Safety Office B901, Marine Corps Air Station Cherry Point, NC

Amendment 0002 is being issued to respond to pre-award RFI.

The deadline to submit pre-award RFI's REMAINS 31 July 2022 at 9:00 AM.

The proposal due date of 10 August 2022 at 12:00 PM local time REMAINS unchanged.

See Attached.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

RFI Responses:

1. Spec section 08 11 13 par 2.1 states that “exterior doors must be tested in accordance with ASTM F2247 or ASTM F2927 to meet the requirements of UFC 4-010-01”. These ASTM standards are for blast resistant openings. Can you please verify if these openings need to be blast resistant, and if so, please provide charge weight, stand-off distance, and rebound.

Response:

Requirement has been removed. See revised spec section 08 11 13 dated 29 JUL 2022. Submit proposals in accordance with RFP, Specifications, Drawings and all amendments.

2. Spec section 08 71 00 par 2.3.14 shows stainless steel door closers. To our knowledge, they do not exist. Par. 2.5 also shows surface door closers to be provided in painted bronze finish. Please advise. If stainless steel closers are chosen, please provide a basis of design.

Response:

Requirement has been removed. See revised spec section 08 71 00 Door Hardware dated 29 July 2022. Submit proposals in accordance with RFP, Specifications, Drawings and all amendments.

3. Spec section 08 71 00 par. 2.5 shows the finishes for the door hardware. The door hardware schedule shows stainless steel base hinges (A5111), which is in contrast to the information provided in par 2.5 (steel hinges in satin bronze). Please advise.

Response:

See revised spec section 08 71 00 Door Hardware dated 29 July 2022. Submit proposals in accordance with RFP, Specifications, Drawings and all amendments. Also a continuation sheet must be provided.

CONTINUATION SHEET

PROJECT TABLE OF CONTENTS

SECTION 08 11 13, STEEL DOORS AND FRAMES is deleted and SECTION 08 11 13, STEEL DOORS AND FRAMES, dated 29 JUL 2022, as shown in the footer, is added to the Project Table of Contents and accompanies this Amendment.

SECTION 08 71 00, DOOR HARDWARE is deleted and SECTION 08 71 00, DOOR HARDWARE, dated 29 JUL 2022, as shown in the footer, is added to the Project Table of Contents and accompanies this Amendment.

SECTION 08 11 13

STEEL DOORS AND FRAMES

08/20

PART 1 GENERAL

1.1 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN WELDING SOCIETY (AWS)

AWS D1.1/D1.1M (2020) Structural Welding Code - Steel

ASTM INTERNATIONAL (ASTM)

ASTM A653/A653M (2020) Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process

ASTM A879/A879M (2012; R 2017) Standard Specification for Steel Sheet, zinc Coated by the Electrolytic Process for Applications Requiring Designation of the Coating Mass on Each Surface

ASTM A924/A924M (2020) Standard Specification for General Requirements for Steel Sheet, Metallic-Coated by the Hot-Dip Process

ASTM C578 (2019) Standard Specification for Rigid, Cellular Polystyrene Thermal Insulation

ASTM C591 (2021) Standard Specification for Unfaced Preformed Rigid Cellular Polyisocyanurate Thermal Insulation

ASTM C612 (2014; R 2019) Standard Specification for Mineral Fiber Block and Board Thermal Insulation

ASTM D2863 (2019) Standard Test Method for Measuring the Minimum Oxygen Concentration to Support Candle-Like Combustion of Plastics (Oxygen Index)

ASTM E1300 (2016) Standard Practice for Determining Load Resistance of Glass in Buildings

ASTM F2247 (2018) Standard Test Method for Metal Doors Used in Blast Resistant Applications (Equivalent Static Load Method)

ASTM F2248 (2012) Standard Practice for Specifying an Equivalent 3-Second Duration Design Loading for Blast Resistant Glazing Fabricated with Laminated Glass

ASTM F2927 (2012) Standard Test Method for Door Systems Subject to Airblast Loadings

BUILDERS HARDWARE MANUFACTURERS ASSOCIATION (BHMA)

ANSI/BHMA A156.115 (2016) Hardware Preparation in Steel Doors and Steel Frames

NATIONAL ASSOCIATION OF ARCHITECTURAL METAL MANUFACTURERS (NAAMM)

NAAMM HMMMA 810 (2009) Hollow Metal Doors

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 80 (2019) Standard for Fire Doors and Other Opening Protectives

NFPA 105 (2019) Standard for Smoke Door Assemblies and Other Opening Protectives

NFPA 252 (2017) Standard Methods of Fire Tests of Door Assemblies

STEEL DOOR INSTITUTE (SDI/DOOR)

SDI/DOOR 111 (2009) Recommended Details for Standard Steel Doors, Frames, and Accessories and Related Components

SDI/DOOR 113 (2013; R2018) Standard Practice for Determining the Steady-State Thermal Transmittance of Steel Door and Frame Assemblies

SDI/DOOR A250.3 (2019) Test Procedure and Acceptance Criteria for Factory Applied Finish Coatings for Steel Doors and Frames

SDI/DOOR A250.4 (2018) Test Procedure and Acceptance Criteria for Physical Endurance for Steel Doors, Frames and Frame Anchors

SDI/DOOR A250.6 (2015) Recommended Practice for Hardware Reinforcing on Standard Steel Doors and Frames

SDI/DOOR A250.8 (2017) Specifications for Standard Steel Doors and Frames

SDI/DOOR A250.11 (2012) Recommended Erection Instructions for Steel Frames

U.S. DEPARTMENT OF DEFENSE (DOD)

UFC 4-010-01

(2018;with Change 1, 2020) DoD Minimum
Antiterrorism Standards for Buildings

UNDERWRITERS LABORATORIES (UL)

UL 10C

(2016; Reprint May 2021) UL Standard for
Safety Positive Pressure Fire Tests of
Door Assemblies

1.2 SUBMITTALS

Government approval is required for all submittals. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Doors

Frames

Accessories

Schedule of Doors

Schedule of Frames

SD-03 Product Data

Doors

Recycled Content for Steel Door Product

Frames

Recycled Content for Steel Frame Product

Accessories

1.3 DELIVERY, STORAGE, AND HANDLING

Deliver doors, frames, and accessories undamaged and with protective wrappings or packaging. Provide temporary steel spreaders securely fastened to the bottom of each welded frame. Store doors and frames on platforms under cover in clean, dry, ventilated, and accessible locations, with 1/4 inch airspace between doors. Remove damp or wet packaging immediately and wipe affected surfaces dry. Replace damaged materials with new.

PART 2 PRODUCTS

2.1 STANDARD STEEL DOORS

SDI/DOOR A250.8, except as specified otherwise. Prepare doors to receive door hardware as specified in Section 08 71 00 DOOR HARDWARE. Undercut

where indicated. Provide exterior doors with top edge closed flush and sealed to prevent water intrusion. Provide doors at 1-3/4 inch thick, unless otherwise indicated. Provide door material that uses a minimum of 25 percent recycled content. Provide data indicating percentage of recycled content for steel door product. Provide exterior glazing in accordance with ASTM F2248 and ASTM E1300.

2.1.1 Classification - Level, Performance, Model

2.1.1.1 Extra Heavy Duty Doors

SDI/DOOR A250.8, Level 3, physical performance Level A, Model 3 with core construction as required by the manufacturer for indicated exterior doors, of size(s) and design(s) indicated. Where vertical stiffener cores are required, the space between the stiffeners must be filled with board insulation.

2.2 CUSTOM HOLLOW METAL DOORS

Provide custom hollow metal doors where nonstandard steel doors are indicated. Provide custom steel doors in the door size(s), design(s), materials, construction, gages, and finish as specified for custom steel doors and complying with the requirements of NAAMM HMMA 810. Fill all spaces in exterior doors with insulation. Close top and bottom edges with steel channels not lighter than 16 gage. Close tops of exterior doors flush with an additional channel and seal to prevent water intrusion. Prepare doors to receive hardware specified in Section 08 71 00 DOOR HARDWARE. Provide doors at 1-3/4 inch thick, unless otherwise indicated. Provide exterior glazing in accordance with ASTM F2248 and ASTM E1300. Exterior doors must be tested in accordance with ASTM F2247 and ASTM F2927 to meet the requirements of UFC 4-010-01.

2.3 INSULATED STEEL DOOR SYSTEMS

Provide insulated steel doors and frames in accordance with SDI/DOOR 113 at entrances to dwelling units and where indicated. Meet energy requirements including Solar Heat Gain Coefficient (SHGC) and U-factor. Provide insulated steel doors with a core of polyurethane foam; face sheets, edges, and frames of galvanized steel not lighter than 23 gage, 16 gage, and 16 gage respectively; magnetic weatherstripping; nonremovable-pin hinges; thermal-break aluminum threshold; and vinyl door bottom. Provide to doors and frames a phosphate treatment, rust-inhibitive primer, and baked acrylic enamel finish. Test doors in accordance with SDI/DOOR A250.4 and meet the requirements for Level C. Prepare doors to receive specified hardware. Provide doors 1-3/4 inch thick.

2.4 ACCESSORIES

2.4.1 Moldings

Provide moldings around glass of interior and exterior doors and louvers of interior doors. Provide nonremovable moldings on outside of exterior doors and on corridor side of interior doors. Other moldings may be stationary or removable. Secure inside moldings to stationary moldings, or provide snap-on moldings.

2.5 INSULATION CORES

Provide insulating cores at all exterior doors, and provide an apparent U-factor of .48 in accordance with [SDI/DOOR 113](#) and conforming to:

- a. Rigid Cellular Polyisocyanurate Foam: [ASTM C591](#), Type I or II, foamed-in-place or in board form, with oxygen index of not less than 22 percent when tested in accordance with [ASTM D2863](#); or
- b. Rigid Polystyrene Foam Board: [ASTM C578](#), Type I or II; or
- c. Mineral board: [ASTM C612](#), Type I.

2.6 STANDARD STEEL [FRAMES](#)

[SDI/DOOR A250.8](#), Level 3, except as otherwise specified. Form frames to sizes and shapes indicated, with welded corners. Provide steel frames for doors, transoms, sidelights, mullions, and interior glazed panels, unless otherwise indicated. Provide frame product that uses a minimum of 25 percent recycled content. Provide data indicating percentage of [recycled content for steel frame product](#).

2.6.1 Welded Frames

Continuously weld frame faces at corner joints. Mechanically interlock or continuously weld stops and rabbets. Grind welds smooth.

Weld frames in accordance with the recommended practice of the Structural Welding Code Sections 1 through 6, [AWS D1.1/D1.1M](#) and in accordance with the practice specified by the producer of the metal being welded.

2.6.2 Knock-Down Frames

Design corners for simple field assembly by concealed tenons, splice plates, or interlocking joints that produce square, rigid corners and a tight fit and maintain the alignment of adjoining members. Provide locknuts for bolted connections.

2.6.3 Mullions and Transom Bars

Provide mullions and transom bars of closed or tubular construction with heads and jambs butt-welded together or knock-down for field assembly. Bottom of door mullions must have adjustable floor anchors and spreader connections.

2.6.4 Stops and Beads

Provide form and loose stops and beads from [20 gage](#) steel. Provide for glazed and other openings in standard steel frames. Secure beads to frames with oval-head, countersunk Phillips self-tapping sheet metal screws or concealed clips and fasteners. Space fasteners approximately [12 to 16 inch](#) on center. Miter molded shapes at corners. Butt or miter square or rectangular beads at corners.

2.6.5 Cased Openings

Fabricate frames for cased openings of same material, gage, and assembly as specified for metal door frames, except omit door stops and preparation for hardware.

2.6.6 Anchors

Provide anchors to secure the frame to adjoining construction. Provide steel anchors, zinc-coated not lighter than 18 gage.

2.6.6.1 Wall Anchors

Provide at least three anchors for each jamb. For frames which are more than 7.5 feet in height, provide one additional anchor for each jamb for each additional 2.5 feet or fraction thereof.

- a. Masonry: Provide anchors of corrugated or perforated steel straps or 3/16 inch diameter steel wire, adjustable or T-shaped;
- b. Stud partitions: Weld or otherwise securely fasten anchors to backs of frames. Design anchors to be fastened to wood studs with nails;
- c. Completed openings: Secure frames to previously placed concrete or masonry with expansion bolts in accordance with SDI/DOOR 111; and
- d. Solid plaster partitions: Secure anchors solidly to back of frames and tie into the lath. Provide adjustable top strut anchors on each side of frame for fastening to structural members or ceiling construction above. Provide size and type of strut anchors as recommended by the frame manufacturer.

2.6.6.2 Floor Anchors

Provide floor anchors drilled for 3/8 inch anchor bolts at bottom of each jamb member.

2.7 EXTERIOR FRAMES

Provide thermal insulation in all exterior frames. Provide frames of a minimum Level 4, with frames of a minimum thickness of 0.067 inch, 14 gage.

2.8 HARDWARE PREPARATION

Drill and tap doors and frames to receive finish hardware. Prepare doors and frames for hardware in accordance with the applicable requirements of SDI/DOOR A250.8 and SDI/DOOR A250.6. For additional requirements refer to ANSI/BHMA A156.115. Drill and tap for surface-applied hardware at the project site. Build additional reinforcing for surface-applied hardware into the door at the factory. Punch door frames to receive a minimum of two rubber or vinyl door silencers on lock side of single doors and one silencer for each leaf at heads of double doors. Set lock strikes out to provide clearance for silencers.

2.9 FINISHES

2.9.1 Factory-Primed Finish

Thoroughly clean all surfaces of doors and frames then chemically treat and factory prime with a rust inhibiting coating as specified in SDI/DOOR A250.8.

2.9.2 Electrolytic Zinc-Coated Anchors and Accessories

Provide electrolytically deposited zinc-coated steel in accordance with [ASTM A879/A879M](#), Commercial Quality, Coating Class A. Phosphate treat and factory prime zinc-coated surfaces as specified in [SDI/DOOR A250.8](#).

2.10 FABRICATION AND WORKMANSHIP

Provide finished doors and frames that are strong and rigid, neat in appearance, and free from defects, waves, scratches, cuts, dents, ridges, holes, warp, and buckle. Provide molded members that are clean cut, straight, and true, with joints coped or mitered, well formed, and in true alignment. Dress exposed welded and soldered joints smooth. Design door frame sections for use with the wall construction indicated. Corner joints must be well formed and in true alignment. Conceal fastenings where practicable. Design frames in exposed masonry walls or partitions to allow sufficient space between the inside back of trim and masonry to receive caulking compound.

2.11 PROVISIONS FOR GLAZING

Materials are specified in Section [08 81 00](#), GLAZING.

PART 3 EXECUTION

3.1 INSTALLATION

3.1.1 Frames

Set frames in accordance with [SDI/DOOR A250.11](#). Plumb, align, and brace securely until permanent anchors are set. Anchor bottoms of frames with expansion bolts or powder-actuated fasteners. Build in or secure wall anchors to adjoining construction.

3.1.2 Doors

Hang doors in accordance with clearances specified in [SDI/DOOR A250.8](#). After erection and glazing, clean and adjust hardware.

3.2 PROTECTION

Protect doors and frames from damage. Repair damaged doors and frames prior to completion and acceptance of the project or replace with new, as directed. Wire brush rusted frames until rust is removed. Clean thoroughly. Apply an all-over coat of rust-inhibitive paint of the same

type used for shop coat.

3.3 CLEANING

Upon completion, clean exposed surfaces of doors and frames thoroughly.
Remove mastic smears and other unsightly marks.

-- End of Section --

SECTION 08 71 00

DOOR HARDWARE

02/16, CHG 3: 08/20

PART 1 GENERAL

1.1 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM E283	(2019) Standard Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen
ASTM F883	(2013) Padlocks

BUILDERS HARDWARE MANUFACTURERS ASSOCIATION (BHMA)

ANSI/BHMA A156.1	(2016) Butts and Hinges
ANSI/BHMA A156.2	(2017) Bored and Preassembled Locks and Latches
ANSI/BHMA A156.3	(2020) Exit Devices
ANSI/BHMA A156.4	(2013) Door Controls - Closers
ANSI/BHMA A156.5	(2020) Cylinder and Input Devices for Locks
ANSI/BHMA A156.6	(2015) Architectural Door Trim
ANSI/BHMA A156.7	(2016) Template Hinge Dimensions
ANSI/BHMA A156.8	(2021) Door Controls - Overhead Stops and Holders
ANSI/BHMA A156.10	(2017) Power Operated Pedestrian Doors
ANSI/BHMA A156.12	(2013) Interconnected Locks & Latches
ANSI/BHMA A156.13	(2017) Mortise Locks & Latches Series 1000
ANSI/BHMA A156.14	(2013) Sliding and Folding Door Hardware
ANSI/BHMA A156.15	(2021) Release Devices Closer Holder, Electromagnetic and Electromechanical
ANSI/BHMA A156.16	(2018) Auxiliary Hardware

ANSI/BHMA A156.17	(2019) Self Closing Hinges & Pivots
ANSI/BHMA A156.18	(2020) Materials and Finishes
ANSI/BHMA A156.19	(2013) Power Assist & Low Energy Power Operated Doors
ANSI/BHMA A156.21	(2019) Thresholds
ANSI/BHMA A156.22	(2017) Door Gasketing and Edge Seal Systems
ANSI/BHMA A156.23	(2010) Electromagnetic Locks
ANSI/BHMA A156.24	(2012) Delayed Egress Locking Systems
ANSI/BHMA A156.25	(2013) Electrified Locking Devices
ANSI/BHMA A156.26	(2012) Continuous Hinges
ANSI/BHMA A156.27	(2011) Power and Manual Operated Revolving Pedestrian Doors
ANSI/BHMA A156.29	(2012) Exit Locks, Exit Alarms, Alarms for Exit Devices
ANSI/BHMA A156.30	(2014) High Security Cylinders
ANSI/BHMA A156.31	(2013) Electric Strikes and Frame Mounted Actuators
ANSI/BHMA A156.36	(2010) Auxiliary Locks

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70	(2020; ERTA 20-1 2020; ERTA 20-2 2020; TIA 20-1; TIA 20-2; TIA 20-3; TIA 20-4) National Electrical Code
NFPA 72	(2019; TIA 19-1; ERTA 1 2019) National Fire Alarm and Signaling Code
NFPA 80	(2019) Standard for Fire Doors and Other Opening Protectives
NFPA 101	(2021) Life Safety Code
NFPA 252	(2017) Standard Methods of Fire Tests of Door Assemblies

STEEL DOOR INSTITUTE (SDI/DOOR)

SDI/DOOR A250.8	(2017) Specifications for Standard Steel Doors and Frames
-----------------	---

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

36 CFR 1191

Americans with Disabilities Act (ADA)
Accessibility Guidelines for Buildings and
Facilities; Architectural Barriers Act
(ABA) Accessibility Guidelines

UNDERWRITERS LABORATORIES (UL)**UL 14C**

(2006; Reprint Jul 2017) UL Standard for
Safety Swinging Hardware for Standard
Tin-Clad Fire Doors Mounted Singly and in
Pairs

UL Bld Mat Dir

(updated continuously online) Building
Materials Directory

1.2 SUBMITTALS

Government approval is required for **all** submittals. Submit the following
in accordance with Section **01 33 00** SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Manufacturer's Detail Drawings

Verification of Existing Conditions

Hardware Schedule

Keying System

SD-03 Product Data

Hardware Items

SD-08 Manufacturer's Instructions

Installation

SD-10 Operation and Maintenance Data

Hardware Schedule Items, Data Package 1

SD-11 Closeout Submittals

Key Bitting

1.3 SHOP DRAWINGS

Submit **manufacturer's detail drawings** indicating all hardware assembly
components and interface with adjacent construction. Base shop drawings on
verified field measurements and include **verification of existing conditions**.

1.4 PRODUCT DATA

Indicate fire-ratings at applicable components. Provide documentation of
ABA/ADA accessibility compliance of applicable components, as required by

36 CFR 1191 Appendix D - Technical.

1.5 HARDWARE SCHEDULE

Prepare and submit hardware schedule in the following form:

Hardware Item	Quantity	Size	Reference Publication Type No.	Finish	Mfr Name and Catalog No.	Key Control Symbols	UL Mark (If fire-rated and listed)	BHMA Finish Designation

In addition, submit hardware schedule data package 1 in accordance with Section 01 78 23 OPERATION AND MAINTENANCE DATA.

1.6 KEY BITTING CHART REQUIREMENTS

1.6.1 Requirements

Submit key bitting charts to the Contracting Officer prior to completion of the work. Include:

- Complete listing of all keys (e.g. AA1 and AA2).
- Complete listing of all key cuts (AA1-123456, AA2-123458).
- Tabulation showing which key fits which door.
- Copy of floor plan showing doors and door numbers.
- Listing of 20 percent more key cuts than are presently required in each master system.

1.7 QUALITY ASSURANCE

1.7.1 Hardware Manufacturers and Modifications

Provide, as far as feasible, locks, hinges, and closers of one lock, hinge, or closer manufacturer's make. Modify hardware as necessary to provide features indicated or specified.

1.7.2 Key Shop Drawings Coordination Meeting

Prior to the submission of the key shop drawing, the Contracting Officer, Contractor, Door Hardware Subcontractor, using Activity and Base Locksmith must meet to discuss and coordinate key requirements for the facility.

1.8 DELIVERY, STORAGE, AND HANDLING

Deliver hardware in original individual containers, complete with necessary appurtenances including fasteners and instructions. Mark each individual

container with item number as shown on hardware schedule.

PART 2 PRODUCTS

2.1 TEMPLATE HARDWARE

Hardware applied to metal or to prefinished doors must be manufactured using a template. Provide templates to door and frame manufacturers in accordance with [ANSI/BHMA A156.7](#) for template hinges. Coordinate hardware items to prevent interference with other hardware.

2.2 HARDWARE FOR FIRE DOORS AND EXIT DOORS

Provide all hardware necessary to meet the requirements of [NFPA 72](#) for door alarms, [NFPA 80](#) for fire doors, [NFPA 101](#) for exit doors, [NFPA 252](#) for fire tests of door assemblies, ABA/ADA accessibility requirements, and all other requirements indicated, even if such hardware is not specifically mentioned in paragraph HARDWARE SCHEDULE. Provide Underwriters Laboratories, Inc. labels for such hardware in accordance with [UL Bld Mat Dir](#) or equivalent labels in accordance with another testing laboratory approved in writing by the Contracting Officer.

2.3 HARDWARE ITEMS

Clearly and permanently mark with the manufacturer's name or trademark, hinges, pivots, locks, latches, exit devices, bolts and closers where the identifying mark is visible after the item is installed. For closers with covers, the name or trademark may be beneath the cover. Coordinate electrified door hardware components with corresponding components specified in Division 28 ELECTRONIC SECURITY SYSTEMS (ESS).

2.3.1 Hinges

Provide in accordance with [ANSI/BHMA A156.1](#). Provide hinges that are [4-1/2 by 4-1/2 inch](#) unless otherwise indicated. Construct loose pin hinges for interior doors and reverse-bevel exterior doors so that pins are non-removable when door is closed. Other anti-friction bearing hinges may be provided in lieu of ball bearing hinges.

2.3.2 Continuous Hinges

Where continuous hinges are required, provide in accordance with [ANSI/BHMA A156.26](#).

2.3.3 Pivots

Provide in accordance with [ANSI/BHMA A156.17](#).

2.3.4 Spring Hinges

Provide in accordance with [ANSI/BHMA A156.17](#).

2.3.5 Locks and Latches

- a. At exterior locations provide locksets of full stainless steel type 302 or 304 construction including fronts, strike, escutcheons, knobs, bolts and all interior working parts. Marine Grade I, fully non-ferrous.

- b. In non-air-conditioned interior environments or humid interior environments, provide interior locksets on the same Marine Grade I, fully non-ferrous as exterior locksets.

2.3.5.1 Bored Locks and Latches

Provide in accordance with ANSI/BHMA A156.2, Series 4000, Grade 1.

2.3.5.2 Auxiliary Locks

Provide in accordance with ANSI/BHMA A156.36, Grade 1.

2.3.6 Exit Devices

Provide in accordance with ANSI/BHMA A156.3, Grade 1. Provide adjustable strikes for rim type and vertical rod devices. Provide open back strikes for pairs of doors with mortise and vertical rod devices.

Use bronze base metal with plated finishes. Also include stainless steel fasteners and screws.

2.3.7 Exit Locks With Alarm

Provide in accordance with ANSI/BHMA A156.3 and ANSI/BHMA A156.29, Type E0431 (with full width horizontal actuating bar) for single doors; Type E0431 (with actuating bar) or E0471 (with actuating bar and top and bottom bolts, both leaves active) for pairs of doors, unless otherwise specified. Provide door alarms integrated with the fire alarm system in accordance with NFPA 72.

2.3.8 Cylinders and Cores

Provide cylinders and cores with seven pin tumblers. Provide cylinders from the products of one manufacturer, and provide cores from the products of one manufacturer. Rim cylinders, mortise cylinders, and knobs of bored locksets have interchangeable cores which are removable by special control keys. Stamp each interchangeable core with a key control symbol in a concealed place on the core.

2.3.9 Push Button Mechanisms

Provide in accordance with ANSI/BHMA A156.5, Grade 1.

2.3.10 Keying System

Provide an extension of the existing keying system. Existing locks were manufactured by BEST and have interchangeable cores.

2.3.11 Lock Trim

Provide cast, forged, or heavy wrought construction and commercial plain design for lock trim.

2.3.11.1 Lever Handles

Provide lever handles where indicated in the Hardware Schedule. Provide in accordance with ANSI/BHMA A156.3 for mortise locks of lever handles for

exit devices. Provide lever handle locks with a breakaway feature (such as a weakened spindle or a shear key) to prevent irreparable damage to the lock when force in excess of that specified in [ANSI/BHMA A156.13](#) is applied to the lever handle. Provide lever handles return to within 1/2 inch of the door face. Provide lever handles in style, color, and material that match existing lever handles.

2.3.11.2 Texture

Provide knurled or abrasive coated knobs or lever handles for doors which are accessible to blind persons and which lead to dangerous areas.

2.3.12 Keys

Furnish one file key, one duplicate key, and one working key for each key change and for each master keying system. Furnish one additional working key for each lock of each keyed-alike group. Stamp each key with appropriate key control symbol and "U.S. property - do not duplicate." Do not place room number on keys.

2.3.13 Door Bolts

Provide in accordance with [ANSI/BHMA A156.16](#). Provide dustproof strikes for bottom bolts, except at doors having metal thresholds. Provide automatic latching flush bolts in accordance with [ANSI/BHMA A156.3](#), Type 25.

2.3.14 Closers

Provide in accordance with [ANSI/BHMA A156.4](#), Series C02000, Grade 1, with PT 4C. Provide with brackets, arms, mounting devices, fasteners, full size covers, except at storefront mounting, and other features necessary for the particular application. Size closers in accordance with manufacturer's printed recommendations, or provide multi-size closers, Sizes 1 through 6, and list sizes in the Hardware Schedule. Provide manufacturer's 10 year warranty.

2.3.14.1 Identification Marking

Engrave each closer with manufacturer's name or trademark, date of manufacture, and manufacturer's size designation in locations that will be visible after installation.

2.3.15 Overhead Holders

Provide in accordance with [ANSI/BHMA A156.8](#).

2.3.16 Door Protection Plates

Provide in accordance with [ANSI/BHMA A156.6](#).

2.3.16.1 Sizes of Kick Plates

2 inch less than door width for single doors; 1 inch less than door width for pairs of doors. Provide 1 inch less than height of bottom rail for panel doors.

2.3.17 Door Stops and Silencers

Provide in accordance with ANSI/BHMA A156.16. Silencers Type L03011. Provide three silencers for each single door, two for each pair.

2.3.18 Padlocks

Provide in accordance with ASTM F883.

2.3.19 Thresholds

Provide in accordance with ANSI/BHMA A156.21. Use J35100, with vinyl or silicone rubber insert in face of stop, for exterior doors opening out, unless specified otherwise.

2.3.20 Weatherstripping Gasketing

Provide in accordance with ANSI/BHMA A156.22. Provide the type and function designation where specified in paragraph HARDWARE SCHEDULE. Provide a set to include head and jamb seals. Air leakage of weatherstripped doors not to exceed 0.5 cubic feet per minute of air per square foot of door area when tested in accordance with ASTM E283. Provide weatherstripping with one of the following:

2.3.20.1 Extruded Aluminum Retainers

Extruded aluminum retainers not less than 0.050 inch wall thickness with vinyl, neoprene, silicone rubber, or polyurethane inserts. Provide bronze anodized aluminum.

2.3.20.2 Interlocking Type

Zinc or bronze not less than 0.018 inch thick.

2.3.20.3 Spring Tension Type

Spring bronze or stainless steel not less than 0.008 inch thick.

2.3.21 Rain Drips

Provide in accordance with ANSI/BHMA A156.22. Provide extruded aluminum rain drips, not less than 0.08 inch thick, bronze anodized finish. Provide the manufacturer's full range of color choices to the Contracting Officer for color selection. Provide rain drips with a 4 inch overlap on each side of each exterior door that is not protected by an awning, roof, eave or other horizontal projection. Set drips in sealant and fasten with stainless steel screws.

2.3.21.1 Door Rain Drips

Approximately 1-1/2 inch high by 5/8 inch projection. Align bottom with bottom edge of door.

2.3.21.2 Overhead Rain Drips

Approximately 1-1/2 inch high by 2-1/2 inch projection. Align bottom with door frame rabbet.

2.3.22 Auxiliary Hardware (Other than locks)

Provide in accordance with ANSI/BHMA A156.16, Grade 1.

2.3.23 Sliding and Folding Door Hardware

Provide in accordance with ANSI/BHMA A156.14, Grade 1. Finishes to match other hardware specified herein.

2.3.24 Special Tools

Provide special tools, such as spanner and socket wrenches and dogging keys, as required to service and adjust hardware items.

2.4 FASTENERS

Provide fasteners of type, quality, size, and quantity appropriate to the specific application. Fastener finish to match hardware. Provide stainless steel or nonferrous metal fasteners in locations exposed to weather. Verify metals in contact with one another are compatible and will avoid galvanic corrosion when exposed to weather.

2.5 FINISHES

Provide in accordance with ANSI/BHMA A156.18. Provide hardware in BHMA 612 finish (satin bronze), unless specified otherwise. Finish surface door closers bronze paint finish. Provide steel hinges in BHMA 639 finish (satin bronze plated). Provide exposed parts of concealed closers finish to match lock and door trim. Match hardware finish for aluminum doors to match the doors. Provide hardware showing on interior of bathrooms, shower rooms, and toilet rooms in BHMA 629 finish (bright stainless steel) or BHMA 625 finish (bright chromium plated).

PART 3 EXECUTION

3.1 INSTALLATION

Provide hardware in accordance with manufacturers' printed installation instructions. Fasten hardware to wood surfaces with full-threaded wood screws or sheet metal screws. Provide machine screws set in expansion shields for fastening hardware to solid concrete and masonry surfaces. Provide toggle bolts where required for fastening to hollow core construction. Provide through bolts where necessary for satisfactory installation.

3.1.1 Weatherstripping Installation

Provide full contact, weathertight seals that allow operation of doors without binding the weatherstripping.

3.1.1.1 Stop Applied Weatherstripping

Fasten in place with color matched sheet metal screws not more than 9 inch on center after doors and frames have been finish painted.

3.1.1.2 Interlocking Type Weatherstripping

Provide interlocking, self adjusting type on heads and jambs and flexible hook type at sills. Nail weatherstripping to door 1 inch on center and to

heads and jambs at 4 inch on center.

3.1.1.3 Spring Tension Type Weatherstripping

Provide spring tension type on heads and jambs. Provide bronze nails with bronze. Provide stainless steel nails with stainless steel. Space nails not more than 1-1/2 inch on center.

3.1.2 Threshold Installation

Extend thresholds the full width of the opening and notch end for jamb stops. Set thresholds in a full bed of sealant and anchor to floor with cadmium-plated, countersunk, steel screws in expansion sleeves. For aluminum thresholds placed on top of concrete surfaces, coat the underside surfaces that are in contact with the concrete with fluid applied waterproofing as a separation measure prior to placement.

3.2 FIRE DOORS AND EXIT DOORS

Provide hardware in accordance with NFPA 72 for door alarms, NFPA 80 for fire doors, NFPA 101 for exit doors, and NFPA 252 for fire tests of door assemblies.

3.3 HARDWARE LOCATIONS

Provide in accordance with SDI/DOOR A250.8, unless indicated or specified otherwise.

- a. Kick and Armor Plates: Push side of single-acting doors. Both sides of double-acting doors.
- b. Mop Plates: Bottom flush with bottom of door.

3.4 FIELD QUALITY CONTROL

After installation, protect hardware from paint, stains, blemishes, and other damage until acceptance of work. Submit notice of testing 15 days before scheduled, so that testing can be witnessed by the Contracting Officer. Adjust hinges, locks, latches, bolts, holders, closers, and other items to operate properly. Demonstrate that permanent keys operate respective locks, and give keys to the Contracting Officer. Correct, repair, and finish, errors in cutting and fitting and damage to adjoining work.

3.5 HARDWARE SETS

Provide the following hardware sets:

HW-1, Doors 101B

1 1/2 Pair	Hinges	A8111
1 Each	FMC Closer	C02021
	with integral Spring Stop	
1 Each	Exit Device with Lever	
	Lever to remain unlocked	F75
1 Each	Drip Ledge	
1 Each	Weatherstrip	
1 Each	Bottom Sweep	

HW-2, Door 101A

1 1/2 Pair	Hinges	A8111
1 Each	FMC Closer	C02021
	with integral Spring Stop	
1 Each	Exit Device with lever	EDF03
	Entry by keyed trim, public use by dogged bar	
1 Each	Cylinder	
1 Each	Drip Ledge	
1 Each	Weatherstrip	
1 Each	Bottom Sweep	

HW-3, Door 105A

1 1/2 Pair	Hinges	A8111
1 Each	FMC Closer	C02021
1 Each	Lever Privacy	F76B
	No Cylinder	
2 Each	8 x 34 Kick Plate	J102
	Coordinate with stile size	
1 Each	Wall Stop	L02251

HW-3, Door 106A

1 1/2 Pair	Hinges	A8111
1 Each	FMC Closer/Stop	C02021
1 Each	Lever Privacy	F76B
	No Cylinder	
2 Each	8 x 34 Kick Plate	J102
	Coordinate with stile size	

HW-4, Door 108A

1 1/2 Pair	Hinges	A8111
1 Each	FMC Closer/Stop	C02021
1 Each	Exit Device with lever	EDF03
	Entry by keyed trim, public use by dogged bar	
1 Each	Cylinder	
1 Each	Drip Ledge	
1 Each	Weatherstrip	
1 Each	Bottom Sweep	
1 Each	Threshold	J35100

HW-3, Door 108B

1 1/2 Pair	Hinges	A8111
1 Each	FMC Closer/Stop	C02021
1 Each	Lever Entry	F109
1 Each	Cylinder	
1 Each	8 x 34 Kick Plate	J102
1 Each	Drip Ledge	
1 Each	Weatherstrip	
1 Each	Bottom Sweep	
1 Each	Threshold	J35100

HW-4, Doors 109A and 110A

1 1/2 Pair	Hinges	A8111
1 Each	Lever Office	F82
1 Each	Cylinder	

-- End of Section --