

1. CONTRACT ID CODE		PAGE		OF PAGES	
J		1		9	
2. AMENDMENT/MODIFICATION NO. 0001		3. EFFECTIVE DATE 08/04/2022		4. REQUISITION/PURCHASE REQ.	
				PROJECT NO. (If applicable)	
6. ISSUED BY NAVFACSYSCOM MID-ATLANTIC PWD NORFOLK FACILITIES ENGINEERING & ACQ DIV 9324 VIRGINIA AVENUE NORFOLK, VA 23511		Code N40085		7. ADMINISTERED BY (If other than item 6.)	
				Code	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				<input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION NO. N40085-22-R-2771	
				<input checked="" type="checkbox"/> 9B. DATED (SEE ITEM 11) 07/15/2022	
				<input type="checkbox"/> 10A. MODIFICATION OF CONTRACT/ORDER NO.	
				<input type="checkbox"/> 10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (if required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
<input type="checkbox"/> A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
<input type="checkbox"/> B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).					
<input type="checkbox"/> C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
<input type="checkbox"/> D. OTHER: (specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not <input type="checkbox"/> is required to sign this document and return copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
N4008522R2771, NSN, BLDG. V-88 CONSTRUCT ROC – DEMOLITION AND ABATEMENT, NORFOLK, VIRGINIA					
SEE SF 30 BLOCK 14 CONTINUATION PAGE					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Same as Item 8)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA	
(Signature of person authorized to sign)				BY	
				(Signature of Contracting Officer)	
				16C. DATE SIGNED	

SECTION SF30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

AMENDMENT 0001

The purpose of this amendment is to provide:

1. Changes to Drawings
2. Site Visit Log
3. Responses to Pre-Proposal Inquiries (PPIs)

All PPIs are hereby answered. All other terms and conditions remain unchanged.

1. Provide Changes to Drawings

See Attachment L - V-88_DWGS_AD101-REV 1

Changes include the following:

The following drawings are revised as of August 03, 2022 and accompany this Design Revision:

<u>NAVFAC Dwg. No.</u>	<u>Title</u>
Architectural	
12,868,894 (AD101)	Overall Floor Plans - Demolition

2. Provide Site Visit Log

See Attachment M – Site Visit Log

3. Provide Responses to PPIs #1-7

PPI #	Date Submitted	LEAVE BLANK	Reference			Question	Response
			Page	Section	Paragraph		
1	07/21/22		Drawing PD 101 and Drawing AD 101	Drawing PD 101 and Drawing AD 101	Drawing PD 101 and Drawing AD 101	Drawing PD 101 indicates the removal of piping from the first floor presumably ceiling area. Drawing AD 101 says the first floor area is not in contract. Assuming that the piping is in the first floor ceiling please provide us a detailed reflected ceiling plan and first floor layout plan if we are to remove and replace existing finishes in this area of piping demolition.	Please see Attachment L - V-88_DWGS_AD101-REV 1, per Amendment 001.
2	07/29/22					Is there a technical proposal for this solicitation?	No. Please refer to the General Requirements, pages 4-5.
3	07/29/22					Is there a bid bond for this solicitation?	Yes, a bid bond is required. Please refer to the General Requirements, pages 4-5
4	08/01/22			n/a	n/a	Can we bring equipment up in the freight elevator for demo use? (electric skid steer and mini excavator)	Equipment can be brought up in the elevator as long as the weight limit of the elevator is not exceeded. But more than likely, one would be limited by the second floor slab's live load capacity which is 150 pounds/SF.
5	08/01/22			n/a	n/a	Can a trash shoot be installed into a dumpster below?	Yes. Location of trash shoot and dumpster would be pending approval of construction site plan by the Government per specifications. Opening for trash shoot during and after demolition work is complete would need to be watertight.
6	08/01/22			n/a	n/a	There is a finished occupied area adjacent to the space. Can this door be shutdown to foot traffic?	No. The door needs to remain operational as an emergency means of egress only. Other than an emergency event, there should be no other foot traffic.
7	08/01/22			n/a	n/a	Does this project require citizenship only?	Per the Specifications, this project does not require citizenship.

(End of Summary of Changes)