

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 2 PAGES	
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0009		3. EFFECTIVE DATE 10/18/22		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable) P1603F	
6. ISSUED BY OFFICER IN CHARGE OF CONSTRUCTION FLORENCE 1121 HAMMOND ROAD CAMP LEJEUNE, NC 28547-2521		CODE ROICC81		7. ADMINISTERED BY (If other than Item 6) See Item 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NO. N6247022R9008	
				X		9B. DATED (SEE ITEM 11) 03/07/22	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 11)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).						
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
	D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
N6247022R9008 P1603F: Bachelor Enlisted Quarter Repairs, M450, Marine Corps Base Camp Lejeune, NC							
The date and the hour for the receipt of proposals remains 26 October 2022 no later than 2:00 pm (EDT).							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)				(Signature of Contracting Officer)			

**Block 14. DESCRIPTION OF AMENDMENT (cont.)**

A. The following provides the Government's responses to pre-award inquiries:

Date Submitted	REFERENCE			QUESTION	GOVERNMENT RESPONSE
	Page	Section	Para.		
10/4/2022				Spec section 08 39 54 paragraph 2.5.1.2 calls for type 1 doors assemblies to meet 17psi with a 57psi-ms impulse in the unseated position. Type 2 requires the assemblies to meet 6 psi with a 37 psi-ms impulse in the unseated position. We have supporting data where our assemblies have been tested to meet the requirement of the type 2 assemblies. We have never tested our assemblies in the unseated position to the levels required by type 1. We have called our assemblies in the seat position to a lever of 43psi. This report would prove our anchorage would hold the frame in the wall, but does not give us any insight on if the hinges would contain the door. The best we could do would be to quote everything as type 2, or the contractor would have to build an alcove so that the door swings out so our assemblies could meet the type 1 requirements. Please advise?	Provide out swinging doors per the attached sketch. Revise associated door hardware as noted.

B. This amendment also incorporates the following updated attachments:

1. Outswing Door Rev

C. All other contract terms and conditions remain unchanged.