

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 2 PAGES	
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0008		3. EFFECTIVE DATE 07/21/22		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable) 20-0075	
6. ISSUED BY CODE		N40085		7. ADMINISTERED BY (If other than Item 6) CODE			
NAVFAC Mid-Atlantic Resident Officer in Charge of Construction 1005 Michael Road Camp Lejeune, NC 28547-2521				See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NO. N40085-22-R-2743	
				X		9B. DATED (SEE ITEM 11) 6/22/22	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 11)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).						
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
	D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) 20-0075, Repair BEQ FC530 Amendment 0008, RFI Responses and Revised Spec Section 08 71 00 The time and date for receipt of proposals is extended to 5 August 2022 at 1400 hours. This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of a proposal. See Continuation Page(s) Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)				(Signature of Contracting Officer)			

CONTINUATION SHEETS

- A. The date and time for receipt of proposals has been extended to 5 August 2022 at 1400 hours.
- B. An updated specification document has been provided with a revised SECTION 08 71 00 DOOR HARDWARE
- C. The following RFI responses have been provided:

1. Question: Demolition Note 4 on Drawing D-103 states "Remove Roof Hatch, prepare opening for new hatch". Construction Note 3 on drawing A-103 states "Provide Roof Hatch". Construction note 12 on A-103 states "Existing Galvanized Steel Ladder and Roof Hatch. Construction Note 7 states "Roof Hatch to Remain". Construction note 13 states "Existing Roof Hatch to remain. Notes 3, 4, and 12 are referring to the access hatch on the shingle roof. Note 7 and 13 are referring to the Attic Floor Hatch. Are new roof hatches required to access the roof? If so, what size.

Answer: Provide new (3'-0" x 4'-0") roof hatches at standing seam pitched roof only. All other roof hatches and ladders in attic are to remain.

2. Question: Construction note 1 on sheet A-103 states "Provide Standing Seam Metal Roof over Vapor Barrier and existing sheathing". The new Construction notes do not show Roof Insulation. Details on A-501 and A-502 show R-25 Roof Insulation with 1/2" Recovery Board. Is new R 25 Roof Insulation and 1/2" Recovery Board required over the entire roof?

Answer: Provide insulation and recovery board per details on sheet A-501 and A-502.

3. Question: Demolition Note 2 on sheet D-103 states "Replace Damaged Roof sheathing. Approximately 1800 sf. Detail "C" on sheet A-502 states "Replace Damaged Sheathing approximately 2000 SF. Which amount is correct?

Answer: 2000SF shall be used as an approximation of roof sheathing replacement.

4. Question: Card Reader locks are mentioned in specification 08 71 00; HW#1 which states "card key system". Please provide specifications for this requirement.

Answer: See revised 08 71 00 specification.

5. Question: As part of 08 71 00, there is a paragraph for mortise locks but no mention of cylindrical locks, however ANSI numbers in HW sets are for cylindrical locks. Please provide clarification.

Answer: See revised 08 71 00 specification.