NAVFAC
SPECIFICATION

7236002
Repairs to BEQ 4310

MCAS Cherry Point, NC
AMENDMENT #0001

IMPORTANT

This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the proposal.

If your proposal has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your proposal is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to proposal opening time.

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT	1. CONTRACT ID CODE	PAGE 1	OF PAGES

2. AMENDMENT/MODIFICATION NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
0001	10/18/2022	7236002	

6. ISSUED BY	Code N40085	7. ADMINISTERED BY (If other than item 6.)	Code
CG MCAS Cherry Point FACILITIES, ROICC B-87, 748 Roosevelt Blvd. PSC BOX 8006 CHERRY POINT, NC 28533			

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	☒	9A. AMENDMENT OF SOLICITATION Repairs to BEQ 4310
		9B. DATED (SEE ITEM 11)
AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL	☐	10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)
CODE / FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☐ **is extended** ☒ **is not extended**. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

☐ A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

☐ B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).

☐ C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

☐ D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

7236002 Repairs to BEQ 4310, Marine Corps Air Station Cherry Point, NC

Amendment 0001 is being issued to respond to pre-award RFI.

The deadline to submit pre-award RFI's REMAINS 28 October 2022 at 9:00 AM.

The proposal due date of 08 November 2022 at 12:00 PM local time REMAINS unchanged.

See attached.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8) (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)	16C. DATE SIGNED

RFI Responses:

1. It is unclear what plumbing pipe and fixtures are to be demolished and what is to remain. Is all of the current pipe and fixtures to be removed and replaced? Please, clarify.

Response: The plumbing drawings and specifications call for the complete replacement of the plumbing system in its entirety. Drawing sheets PD101-PD105 outline the complete demolition of the existing plumbing systems and Drawing sheets P101-P106, P502, P601 and P701-P703 define the new work for replacing all piping and fixtures. Also refer to specification section 22 00 00 -Plumbing, General purpose for further plumbing requirements. Submit proposals in accordance with RFP, Specifications, Drawings, and all Amendments.